

From: Brenda Hanson <BHanson@moosejaw.ca>

Sent: August 12, 2022 5:20 PM

To: [REDACTED]

Subject: New Rock Development - Enquiry re Drainage into Sanitary Sewer System

Dear [REDACTED],

Thank you for your enquiry respecting the above noted.

As we discussed on the telephone, unfortunately, drainage into the Sanitary Sewer System is prohibited as per Bylaw 5524, The Building Bylaw.

I've attached Bylaw 5524 The Building Bylaw for your reference. On Page 17 of the Bylaw, I found the following which answers your enquiry.

Drainage into Sanitary Sewer System Prohibited

- 9.10 No person shall construct downspouts or a drainage system which drains Storm Drainage into the City's sanitary sewer system.
- 9.11 Drainage tile at the footing level of a basement is required to connect to a sump pit. The owner is responsible for pumping out the pit when necessary, and discharging this water to the front or rear of the Property.

Should you have any further enquiries respecting this Bylaw, please contact the Planning and Development Dept. They can be reached by calling 306-694-4443.

Sincerely,



Brenda Hanson

Clerk Steno, Engineering Services

T:306.694.4596 E: bhanson@moosejaw.ca

City of Moose Jaw | 228 Main St. N | Moose Jaw SK | S6H 3J8 | www.moosejaw.ca



CONFIDENTIALITY NOTICE: This e-mail was intended for a specific recipient. It may contain information that is privileged, confidential, or exempt from disclosure. Privilege and confidentiality is not waived. If the reader is not the intended recipient, use or distribution of this information is prohibited. If you have received this communication in error, please notify the sender by telephone or return e-mail and permanently delete or destroy all copies of the message.